



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA2865	5.6	ECLH Horizontal Sidewall	QR	3mm	1/2	Brass, Chrome, Bright Brass, Black Plated, Polyester, Zinc Plated	135°, 155°, 175°F (57°, 68°, 79°C)

Prepared for: Reliable Automatic Sprinkler Co. Inc., 1470 Smith Grove Rd., Liberty, SC 29657

Manufacturing Location: Reliable Automatic Sprinkler Co. Inc., 1470 Smith Grove Rd., Liberty, SC 29657

FM Approval Class: 2022

FM Approval Standard: Class Series 2000 (October 2006)

Project Identifier:

3036789

Date of Approval:

November 23, 2009

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne, Manager

Hydraulics Group

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

November 25, 2009



Member of the FM Global Group