



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6222	8.0	Upright	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6322	8.0	Upright	QR	3 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2043

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6212	8.0	Pendent	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6212	8.0	In-Rack Pendent	SR	5 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA6212	8.0	Recessed Pendent	SR	5 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2015, 2005, 2043  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA6312	8.0	Pendent	QR	3 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6312	8.0	In-Rack Pendent	QR	3 mm	3/4	Brass, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA6312	8.0	Recessed Pendent	QR	3 mm	3/4	Brass, Chrome, Polyester, Electroless Nickel PTFE (ENT)	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2001, 2015, 2005, 2043

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following equipment:

## Sprinkler Guards for Automatic Control Mode Sprinklers for Fire Protection

Model	Type	Sprinklers FM Approved with	Sprinkler Type
C-1	Guard	RA6212, RA6222, RA6312, RA6322	Upright and pendent automatic sprinklers
C-3	Guard/Shield	RA6222, RA6322	Upright automatic sprinklers
C-5	Guard/Shield	RA6212, RA6312	Pendent automatic sprinklers

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2091

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3055919

Approval Granted: November 3, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group