

APPROVED

Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1335	5.6	Recessed Horizontal Sidewall	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200 (57, 68, 79, 93)
RA1435	5.6	Recessed Horizontal Sidewall	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

FM Approvals Class: 2015
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376 Approval Granted: July 16, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1335	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA1435	5.6	Horizontal Sidewall	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657

FM Approvals Class: 2012
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376 Approval Granted: July 16, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the
constrictions as shown in the Approval Guide, an online resource of FM Approvals.


*For more than 160 years FM Approvals has partnered with business and industry
to reduce property losses.*

A handwritten signature in dark ink, appearing to read "Richard B. Dunne", is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



APPROVED

Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1325	5.6	Upright	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA1425	5.6	Upright	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove
Road, Liberty, SC 29657

FM Approvals Class: 2016
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376 Approval Granted: July 16, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the
constrictions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry
to reduce property losses.*

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group