



APPROVED

# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1335	5.6	Recessed Horizontal Sidewall	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200 (57, 68, 79, 93)
RA1435	5.6	Recessed Horizontal Sidewall	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

FM Approvals Class: 2015  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376      Approval Granted: July 16, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1335	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA1435	5.6	Horizontal Sidewall	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove  
Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove  
Road, Liberty, SC 29657

FM Approvals Class: 2012  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376      Approval Granted: July 16, 2012


Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the  
constrictions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry  
to reduce property losses.*

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



**APPROVED**

# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
RA1325	5.6	Upright	SR	Job G5 5mm	1/2	Polyester Coated	135, 155, 175, 200, 286, 360 (57, 68, 79, 93, 141, 182)
RA1425	5.6	Upright	QR	Job F3 3mm	1/2	Polyester Coated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC 29657

FM Approvals Class: 2016  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046376      Approval Granted: July 16, 2012

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constrictions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group