

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-S5046

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

Model A and D Dry Alarm Valves Dry Alarm Valves

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

The Reliable Automatic Sprinkler Co., Inc,
1470 Smith Grove Road
Liberty
South Carolina
29657
USA

The Reliable Automatic Sprinkler Co., Inc,
1470 Smith Grove Road
Liberty
South Carolina
29657
USA

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12259-3:2000 including amendment +A2:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 28 January 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



Sarah Colwell, Director, Fire Suppression Testing and
Certification
On behalf of BRE Global Limited

Date of First Issue: 28 January 2022

Issue Date: 28 January 2022

Issue Number: 1

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com


APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-S5046**Model A and D Dry Alarm Valves**
Dry Alarm Valves

| Model | Nominal size (mm) | Maximum Working Pressure (bar) | Orientation |
|------------------|-------------------|--------------------------------|---------------|
| A ⁽¹⁾ | 65 | 12 | Vertical only |
| D ⁽²⁾ | 100 and 150 | 12 | Vertical only |

Note:

⁽¹⁾ With threaded inlet and outlet.

⁽²⁾ With flanged inlet and flanged or grooved outlet.



Sarah Colwell, Director, Fire Suppression Testing and
Certification
On behalf of BRE Global Limited

Date of First Issue: 28 January 2022

Issue Date: 28 January 2022

Issue Number: 1

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com