

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20161206-EX454  
**Report Reference** EX454-20110408  
**Issue Date** 2016-DECEMBER-06

**Issued to:** RELIABLE AUTOMATIC SPRINKLER CO INC  
1470 SMITH GROVE RD  
LIBERTY SC 29657

**This is to certify that  
representative samples of**

SPRINKLERS, AUTOMATIC AND OPEN  
SIN RA5994, RA4014, ½ in. NPT, K = 5.6, SIN RA3415, ½  
in. NPT, K = 4.9, SIN RA3413, 1/2 in. NPT, K=4.2,  
RA3412, 3/4 in. NPT, K = 8.0, and SIN RA3411, 1/2 in. NPT,  
K=2.8 concealed pendent, RA4762, 3/4 in. NPT, K = 8.0  
concealed horizontal sidewall, RA5035, K = 5.6 concealed  
horizontal sidewall ordinary hazard fusible solder link type  
heat responsive element. These sprinklers are for use in for  
wet systems only and consists of the following models,  
types, and temperature ratings.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 199 and ULC/ORD-C199-03, Automatic Sprinklers for  
Fire-Protection Service

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

