



# Certificate of Compliance

This certificate is issued for the following equipment:

## Quick Response Storage Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
R602	25.2	Pendent	QR (ESFR) Storage	Fusible	1" NPT or 1" IGS*	Brass	165, 212 (74, 100)

*\*for use with the Style V9 FireLock IGS sprinkler coupling*

Prepared for: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove  
Road, Liberty, SC 29657, USA

Manufacturing Location: The Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove  
Road, Liberty, SC 29657, USA

FM Approvals Class: 2026  
FM Approval Standard: Class Number 2008 (February 2018)

Approval Identification: PR452399

Approval Granted: November 5, 2021

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group

