

Certificate of Compliance

This certificate is issued for the following equipment:

Quick Response Storage Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
R610	33.6	Pendent	QR (ESFR) Storage	Fusible	1-1/4 NPT, 1-1/4 Grooved	Brass	165, 212 (74, 100)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2037

FM Approval Standard: Class Number 2008 (November 2024) and Draft Performance Requirements for Quick Response Standard-Coverage Pendent Storage Automatic Sprinklers with a Nominal Discharge Coefficient of 33.6 gal/min/(psi)^{1/2}[480 L/min/(bar)^{1/2}] dated March 13, 2020

Approval Identification: PR453574

Approval Granted: 8 October 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink, appearing to read 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062 USA

