



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R2921	11.2	Upright	SR	Fusible	1/2, 3/4	Brass, Chrome, Zinc Plated	165, 212, 286 (74, 100, 141)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2009

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR463206

Approval Granted: 1 February 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA

