

Certificate of Compliance

Certificate Number:

EX28316

Report Reference:

EX28316-2020-03-23

Issue Date:

2024-01-22

Issued to:

RELIABLE AUTOMATIC SPRINKLER CO. INC.
1470 Smith Grove Rd.
Liberty, SC 29657 USA

This certificate confirms that representative samples of:

Check Valves

See addendum for model information

Has been evaluated by UL LLC and/or ULC Inc. in accordance with Standard(s) for Safety:

ANSI/CAN/UL/ULC 312 – Check Valves for Fire Protection Service

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark and/or ULC Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark and/or ULC Mark.

Only those products bearing the UL Mark and/or ULC Mark should be considered as being UL Certified and/or ULC Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark and/or ULC Certification Mark on the product.



David Piecuch
UL Mark Certification Program Owner
UL LLC



Gunsimar Paintal
ULC Mark Certification Program Manager
Underwriters Laboratories of Canada Inc.

Certificate of Compliance

Certificate Number: EX28316
Report Reference: EX28316-2020-03-23
Issue Date: 2024-01-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Valve Seat Facing	Nom Pipe Size, NPS	End Configuration	Rated Pressure, psig (kPa)	Installation Position	Notes
REL-50GG	Elastomeric	2; 2-1/2; 3; 4; 5; 6; 8; 10; 12	Groove by Groove	365 (2516)	Horizontal; Vertical	--
REL-50GGP	Elastomeric	2; 2-1/2; 3; 4; 5; 6; 8; 10; 12	Groove by Groove	365 (2516)	Horizontal; Vertical	--

]