



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R601*	22.4	In-Rack Pendent	QR (ESFR)	Fusible	1	Brass	165, 212 (74, 100)
R602*	25.2	In-Rack Pendent	QR (ESFR)	Fusible	1	Brass	165, 212 (74, 100)

**Available with an IGS grooved connection for use with the Style V9 FireLock IGS sprinkler coupling*

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657

FM Approvals Class: 2005

FM Approval Standard: Class Number 200 (February 2018) and Class Number 2008 (February 2018)

Approval Identification: PR455611

Approval Granted: January 10, 2022

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group

