



# Certificate of Compliance

## Automatic Control Mode Sprinklers for Fire Protection

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temp. Ratings °F (°C)
RA1325	5.6	Upright	SR	5 mm	1/2	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated	135°, 155°, 175°, 200°, 286°, 360°F (57°, 68°, 79°, 93°, 141°, 182°C)
RA1425	5.6	Upright	QR	3 mm	1/2	Brass, Chrome, Bright Brass, Zinc Plated	135°, 155°, 175°, 200°, 286°F (57°, 68°, 79°, 93°, 141°C)
RA3125	5.6	Rack Storage Upright	SR	5 mm	1/2	Brass	135°, 155°, 175°, 200°, 286°, 360°F (57°, 68°, 79°, 93°, 141°, 182°C)
RA3195	5.6	Upright	QR	3 mm	1/2	Brass	135°, 155°, 175°, 200°, 286°F (57°, 68°, 79°, 93°, 141°C)

Manufactured by:

The Reliable Automatic Sprinkler Co., Inc.

Manufacturing Location:

1470 Smith Grove Road, Liberty, SC 29657

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 2000 (March 2006)

Project Identifier:

3031070

Date of Approval:

May 12, 2009



Member of the FM Global Group

Richard B. Dunne  
Group Manager - Hydraulics

Date

*May 13, 2009*