



Certificate of Compliance

Automatic Control Mode Sprinklers for Fire Protection

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temp. Ratings °F (°C)
RA1314	5.6	Pendent	SR	5 mm	1/2	Black Plated, Brass, Bright Brass, Chrome, Polyester, Zinc Plated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
RA1414	5.6	Pendent	QR	3 mm	1/2	Black Plated, Brass, Bright Brass, Chrome, Polyester, Zinc Plated	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Manufactured by:

The Reliable Automatic Sprinkler Co., Inc.

Manufacturing Location:


1470 Smith Grove Rd., Liberty, SC 29657


FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 2000 (March 2006)

Project Identifier: 3031450

Date of Approval: September 29, 2008


Richard B. Dunne
Group Manager - Hydraulics


Date



Member of the FM Global Group